



P.O. Box 2400
 Cookeville, Tennessee 38502-2400
 Phone: 931-372-8871
 Fax: 931-525-3896

Odor Emission Test Report

Test Number: RD172125OE

Date of Test: August 18, 2017

Specimen Number: 1652170809-1,10

Date of Manufacture: Unknown

Description of Test Specimen: Quiet-Tech Acoustic Insulation Batt

Test Method: ASTM C 1304-08 (Reapproved 2013) "Test Method for Assessing the Odor Emission of Thermal Insulation Materials".

Report Prepared For: CarpetCycle, LLC / Mr. Robert Phillips

Judge	1	2	3	4	5
Odor (Yes/No)	Yes	No	Yes	Yes	Yes
Odor (Objectionable/Pleasant/Otherwise)	Otherwise		Otherwise	Objectionable	Objectionable
Odor (Weak/Strong)	Weak		Weak	Weak	Weak

Pass / Fail

Pass


 Review: _____

10/5/17
 Date: _____