



16015 Shady Falls Road
Elmendorf, TX 78112
Phone: (210) 635-8100
Fax: (210) 635-8101

ASTM C518 PRELIMINARY RESULTS

TO: Sean Ragiell, CarpetCycle, LLC
DATE: October 14, 2016
PROJECT NO.: 102761257SAT-001
PRODUCT: 2-inch thick insulation material

	Test 1	Test 2	Test 3	Average
Thickness (in.)	2.00	2.00	2.00	2.00
R-Value($^{\circ}\text{F} \cdot \text{ft}^2 \cdot \text{h}/\text{Btu}$)	6.57	6.70	6.95	6.74

If this transmission was incomplete, please notify by telephone at (210) 635-8100.

"The information in this document is confidential and is being transmitted to and is intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, please be advised that any dissemination, distribution or copying of this transmission is strictly prohibited. If you received this document in error, please advise us immediately by telephone and destroy this document."